

Office of the  
Executive Engineer, Electrical Inspectorate, Haryana,  
526/19, Shivaji Nagar, Opp. S.D Public School (Khandsa Road),  
Gurugram (e-mail: [xenceiggn@gmail.com](mailto:xenceiggn@gmail.com)).

To

M/s Salwan Montessori School  
Sector-05,  
Gurugram.

Application No. 6919-4221

Dated: 19/06/2023

Memo No: 10513

Dated: 5.7.23


Subject: Annual inspection of installation comprising of 1x30 KVA D.G Set under Rule Central Electricity Authority (Measures relating to Safety and Electric Supply) Regulations, 2010 for the year 2023 (from Jan 2023 to Dec 2023).

The subject cited installation was inspected by this department on 05.07.2023 and the same was found generally complying with the relevant provisions of CEA (Measures Relating to Safety and Electric Supply) Regulations, 2010. However you are advised that ELCB be provided in lighting circuits.

Consistent compliance of the relevant provisions of CEA Regulations, 2010 be ensured in the installation at your end and the electrical installation be maintain and operated in a condition free from danger and as recommended by the manufacturer or by the relevant code of practice of the Bureau of Indian Standards.

You are further advised to install the smart meter to read the energy generated and send the monthly statement of the units generated from your DG Sets to this department.

Note:- It is advised that running of D.G set is without prejudice to Government terms and condition/Regulation & Norms.

  
Executive Engineer  
Executive Engineer Haryana,  
1st Electrical Inspectorate, Haryana,  
Opp. S.D Public School, Gurugram-1